

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Raindrop

(Name of Officers with designation) from Amesh G.R., Manager PHED

inspected the water purifier

(Name & Address of the school) on 22/05/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. GAL/05/5575 dated 24/05/2025

of PHED (PHED Lab) certified that the

Nargund International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 24/05/2026

**RAIN DROP**  
Ground Floor, Flat No. 2/3,  
Sannathammanahalli,  
Opp. St. Anthony Church, T.C. Palya,  
Bengaluru, Karnataka - 560036.  
M: 9036677444 / 9035677444...

Signature with Seal: .....

Name : .....

Designation : .....

Name & Address of the Office / Department : .....

To

**Nargund International School**

(Name & Address of the Institution)

B.S.K. 3rd Stage, Dattatreyanagar,

Bangalore - 560 085.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





# GLOBAL ANALYTICAL LABORATORY

ISO 9001:2015

#33/2, Shop No 13, C R S Building, C Ramaiah Layout, Ramachandrapura Main Road,  
Vidyaranyapura, Bangalore - 560 097 Mob 9686489581, 9353921722  
E-mail: globaltestinglab2020@gmail.com



## PHYSICAL & CHEMICAL ANALYSIS REPORT

Report No: GAL /05/5575

Issued To : M/S NARAGUND INTERNATIONAL SCHOOL

Address : DATTATREYNAGAR , BANASHANKARI

3<sup>RD</sup> STAGE ,BENGALURU - 560085

Report Date: 24.05.2025

Sample Collected On :22.05.2025

Sample Tested On: 22.05.2025

Sample Particulars: RO - WATER

The water sample submitted by client & analyzed by us with the following results :

SAMPLE DESCRIPTION: Colorless, Odorless, and Transparent Liquid

TESTS (As per IS 10500:2012)	RESULTS	Maximum RO - LIMITS (In mg/l)	Maximum Acceptable Limits (In mg/l)	Protocol IS-3025
1 Color, Hazen Units	<0.01	0.01	5	IS-3025/Part-4
2 Odor	Agreeable	Agreeable	Agreeable	IS-3025/Part-5
3 Turbidity, NTU	0.00	0.00	1	IS-3025/Part-10
4 PH Value	6.9	5.5 - 9	6.5 - 8.5	IS-3025/Part-11
5 Total Hardness as CaCO <sub>3</sub> , mg/l	17	20	200	IS-3025/Part-21
6 Calcium as Ca, mg/l	5.25	6	75	IS-3025/Part-40
7 Magnesium as Mg, mg/l	0.84	1	30	IS-3025/Part-46
8 Chloride as Cl, mg/l	16.9	20	250	IS-3025/Part-32
9 Total Dissolved solids, mg/l	75	80	500	IS-3025/Part-16
10 Sulphate as SO <sub>4</sub> , mg/l	0.00	0.00	200	IS-3025/Part-24
11 Nitrate as NO <sub>3</sub> , mg/l	0.92	1	45	IS-3025/Part-34
12 Fluoride as F, mg/l	0.00	0.00	1.0	IS-3025/Part-60
13 Iron as Fe, mg/l	0.00	0.00	0.3	IS-3025/Part-53
14 Chromium as Cr, mg/l	0.00	0.00	0.05	IS-3025/Part-52
15 Zinc as Zn, mg/l	0.00	0.00	5.0	IS-3025/Part-49
16 Copper as Cu, mg/l	0.00	0.00	0.05	IS-3025/Part-42
17 Manganese as Mn, mg/l	0.00	0.00	0.1	IS-3025/Part-59
18 Residual Free Chlorine, mg/l	0.00	0.00	0.2	IS-3025/Part-26
19 Total Alkalinity as CaCO <sub>3</sub> , mg/l	37	50	200	IS-3025/Part-23
20 Total Suspended Solids, mg/l	0.00	0.00	10	IS-3025/Part-16
21 Silica as SiO <sub>2</sub> , mg/l	0.00	-----	-----	IS-3025/Part-35

## MICROBIOLOGICAL TEST

01	Total Coli form, MPN / 100ml	Absent	Not Detectable	Not Detectable	IS-1622-1981
----	------------------------------	--------	----------------	----------------	--------------

Remarks: The given water sample Microbiologically Safe.

REMARK: The given sample above parameters are tested as per IS 10500 -2012 and it is Physical,  
Chemical Test. The water confirms IS - RO Limits , Water is safe for Drinking.

\*\*\*\*\* End of the Report \*\*\*\*\*

Tested By

Authorised Signature

Note : 1. The Results listed above pertain only to the tested samples and applicable parameters. 2. Samples will be store for a period of 15 days unless otherwise specified. 3. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without prior written permission. 4. Sampling not done by us unless specified.





## **BRUHAT BENGALURU MAHANAGARA PALIKE.**

Medical officer health, Padmanabhanagara Division, BBMP Building, 1<sup>st</sup> Floor,  
KSRTC Layout, Near Sir. M. Vishwesharaiah Play Ground, Bangalore - 560061.

No:MOH/PNN/PR/ 65 /2025-26

Dated: 31/05/2025

### **HEALTH AND SANITATION CERTIFICATE**

This No Objection certificate is issued to **Nargund International School** located at Dattatreyanagar, 1<sup>st</sup> Main, Opp. Dattatreya Temple, 100 Feet Ring Road, Hoskerehalli, BSK 3<sup>rd</sup> Stage, Bangalore – 560085.

This School has to have provision for

1. Clean, Safe, Potable and Sufficient drinking Water.
2. Separate toilet facilities for boys and girls in each floor.
3. Emergency medical first aid Services.
4. Fire and safety measures.
5. Playground Facilities.
6. Emergency Tie up with Nearest Hospital.

The Authorities have paid on amount of Rs. 4,500/- **Vide Receipt no. 000003**  
**Dated: 31/05/2025**, SBI Bank, Water Tank Circle, Kathriguppe Branch DD  
No. 220860 Dated 29/05/2025 Remitted to BBMP Commissioner A/c on  
31/05/2025. The above Certificate is Valid till **31/03/2026** and can be  
revoked at any time, if any violations noted or any complaint arises.

The above is valid for a period of **31/05/2025 to 31/03/2026**

*Hesurud*  
Medical Officer of Health  
Padmanabhanagar Range,  
BBMP, Bangalore.  
ಬಿ.ಕೆ.ಎ.ಕೆ.